



CITY OF COCONUT CREEK

FINANCE AND ADMINISTRATIVE SERVICES

PURCHASING DIVISION

4800 WEST COPANS ROAD
COCONUT CREEK, FLORIDA 33063

ADDENDUM NO. 1

April 11, 2018

Bid No.: 04-18-18-11
Bid Name: City Hall (Lobby) Renovation Phase III
Due Date/Time: Wednesday, April 18, 2018 at 11:00 a.m. EST

Our records indicate that your firm is in receipt of bid documents for Bid No. 04-18-18-11, City Hall (Lobby) Renovation Phase III. The following information is being transmitted to address questions to the IFB. This Addendum is hereby made part of the specifications and shall be included with all contract documents.

1. Questions and Answers (1 through 4)

This addendum acknowledgment sheet must be submitted electronically with your bid response through the eBid System by the due date and time indicated above. Failure to return this sheet may disqualify Bidder.

Bidder's Signature

Date

Company Name

Company Address

() _____
Phone Number

() _____
Fax Number

LINDA JEETHAN
Purchasing and Contracts Manager
ljeethan@coconutcreek.net

**CITY OF COCONUT CREEK
CITY HALL (LOBBY) RENOVATION PHASE III
BID NO. 04-18-18-11**

ADDENDUM NO. 1

Questions and Answers:

Q1: Please confirm the need for builders risk insurance.

A1: Builders risk insurance is not required.

Q2: Ref Sheet E.6 – The graphics indicate purchase by Owner and installed by MFG. Please confirm this scope is excluded from our bid.

A2: The graphics GRF-1, GRF-2, GRF-3, GRF-4 and GRF-5 are not in the scope of this project. However, the walls must be prepared according to the special condition listed on A-6.

Q3: Please clarify the comment from the pre-bid meeting regarding the toilet/bathroom accessories. Confirm they are they Owner furnished and installed. Please confirm which accessories will be by Owner.

A3: All toilet/bathroom fixtures (toilets, sinks, urinals, powered hand dryers, stall systems, etc.) noted in the plans are the responsibility of the Contractor. All toilet/bathroom accessories (toilet paper holders, paper towel dispensers, soap dispensers, and mirrors) will be provided and installed by the City.

Q4: Please provide specification change for the wall hung fixtures

A4: Page A-6, please replace AC-5 Kohler Kingstone white wall hung toilet, with Kohler Highcliff k-96057 white 4 bolt elongated flushometer bowl.